

EMB-SR 60-120

Available only in one version which allows manual bypass operations on 60 to 120kVA three phase UPS. The device comes with three circuit breakers as shown in the attached diagram, so as to ensure complete isolation of the UPS during maintenance or removal operations, whilst guaranteeing continuous power supply to the loads.

The device has a microswitch for connection to the appropriate UPS input, which signals closure of the manual bypass, in order to prevent energy being supplied simultaneously from the manual bypass and the inverter.

